

Emergency Evacuation Route

Learn about elements of a good emergency evacuation floor plan by moving your mouse over the items listed below.

Designate Primary & Secondary Exits

Your evacuation floor plan should designate at least one primary exit and one secondary exit. These exits must be remote from each other and so arranged as to minimize any possibility that both may be blocked by any one fire or other emergency condition.

No Emergency Exits in Restrooms

Even if there is a door in a restroom that employees could exit out of, no emergency exits are designated through restrooms for evacuation of a building. Windows are never designated as exits. Consequently, the floor plan does not indicate the restroom as an exit.

Exit Away From Rooms With Hazardous Materials

Emergency exit routes lead away from this room containing potentially hazardous materials so that no employee will be forced to pass the area during an emergency.


No Emergency Exits Into Narrow Passages

This short passageway between the two buildings may not provide enough open space for safe evacuation during an emergency. Accordingly, no emergency exit leads to this narrow space.

Exit Signs Indicating the Nearest Emergency Exit

Signs reading "Exit" with an arrow indicating the directions, must be placed in every location where the direction of travel to reach the nearest exit is not immediately apparent.

EXAMPLE:



https://www.osha.gov/SLTC/etools/evacuation/floorplan_demo.html

Drag shape to create your office layout

Copy, change size, or colors as needed

ELEV

FIRST AID

or

FIRE

HAZARDOUS

PERSON

Additional Shapes Use Function:

Insert

Page Layout

Picture

Clip Art

Shapes